

POOL/SPA DAILY MAINTENANCE LOG

CA Code of Regulations, title 22, section 65523:

(a) The operator of each pool open for use shall keep a daily record of information regarding operation, including readings of disinfectant (e.g., chlorine) residual, pH, and maintenance procedures such as cleaning of filters and quantity of chemicals used.

(b) If cyanuric acid (stabilizer) is added to the pool, the concentration shall be measured a minimum of once per month and records shall be kept of the results.

Pool Address:		Req. flow rate (gpm):		
Month:		Year:		
Date	Chlorine residual (free chlorine)	pH	Chemicals Added (type and amount)	Other Maintenance (backwash etc.)
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				
26				
27				
28				
29				
30				
31				

Monthly Cyanuric Acid test: Date: _____ Results: _____

Reminders

<u>Chlorine:</u> Min. 2.0 ppm with cyanuric acid 1.0 ppm without cyanuric acid	<u>pH:</u> 7.2 – 7.8 Ideal 7.4 - 7.6	<u>Cyanuric acid:</u> Should not exceed 100 ppm Ideal 20-50 ppm	<u>Maximum water temperature</u> 104 ° F
--	--	---	---

Questions? Please call Nevada County Environmental Health at (530) 265-1222